



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL  
PROTECTION

CN-029, Trenton, N.J., 08625-0029

RECEIVED

JUL 20 1994

PORZIO BROMBERG  
& NEWMAN

CHRISTINE TODD WHITMAN  
Governor

ROBERT C. SHINN, JR.  
Commissioner  
July 18, 1994

Lisa Murtha Bromberg, Esquire  
Porzio, Bromberg and Newman  
163 Madison Avenue  
Morristown, New Jersey 07962-1997

Re: Treatment Works Approval (TWA) Permit No. 90-4939-4L  
Hexcel Corporation, 205 South Main Street  
Borough of Lodi, Bergen County, New Jersey.

Dear Ms. Bromberg,

Reference is made to your June 10, 1994 letter in which you requested the applicability of the newly adopted treatment works approval regulations at N.J.A.C. 7:14A, Subchapter 22 on the above noted project.

It is the belief of the Bureau of Construction and Connection Permits (BCCP) that the original TWA permit number 90-4939-4L did include permission to construct and operate a sewer connection to the Passaic Valley Sewerage Commissioners' collection system as well as the contaminated groundwater treatment process. That permit remains in effect until December 31, 1994, at which time the Permit Extension Act and said TWA permit will expire.

Pursuant to N.J.A.C. 7:14A - 22.4 (b) et seq., a TWA permit from the Department would no longer be needed for the contaminated groundwater treatment process, since the treated groundwater will directly discharge into a publicly owned treatment works and will be located in an area of the State for which the Department is not the control authority (delegated area) for the industrial pretreatment program.

Also, pursuant to N.J.A.C. 7:14A - 22.4 (b) et seq., a TWA permit from the Department would no longer be needed for the sewer connection, since you are not proposing to construct a sewer extension which (1) will extend along an easement through more than two properties, a roadway or public right-of-way; (2) conveys flows from more than two buildings; or (3) conveys or will convey 8,000 gallons per day or more of treated groundwater.

Based upon the above, Hexcel Corporation is not required to receive future Department approval for this proposed project. However, Hexcel Corporation must be in compliance with all applicable requirements of the Borough of Lodi and the Passaic Valley Sewerage Commissioners.




Lisa Murtha Bromberg, Esquire  
Porzio, Bromberg and Newman  
Treatment Works Approval (TWA) Permit No. 90-4939-4L  
July 18, 1994  
Page 2 of 2

Finally, any change in the project scope which will result in the facility to become regulated pursuant to N.J.A.C. 7:14A, Subchapter 22, shall not be initiated prior to receiving written approval from the Department.

If you have any questions regarding this matter, please contact the undersigned by calling (609) 984-4429.

Sincerely,



Helen L.L. Rancan, Principal Environmental Engineer  
Bureau of Construction and Connection Permits  
Wastewater Facilities Management Program

WFM272

Enclosure

90-4939-4L

c: Borough of Lodi  
Passaic Valley Sewerage Commissioners

883110002